



## FIRE RESISTANT TIMBER FIRE DOORS

*Certificate number: IFCC 1097*

This is a product certificate to certify that

***Humphrey & Stretton plc***

Pindar Road, Hoddesdon,  
Hertfordshire,  
EN11 0EW  
+44 (0)1992 462965

Who fabricate the following fire doors:

<b>Halspan FD30</b>	<b>Halspan FD90</b>
<b>Halspan FD60</b>	<b>Halspan FD120</b>
<b>Strebord FD30</b>	<b>Strebord FD60</b>

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06 also SS01, SS02



First Issued: 19<sup>th</sup> September 2014  
Valid to: 18<sup>th</sup> September 2019  
Issue No: 1



175

A handwritten signature in black ink, appearing to read 'Bob Williams'.

Bob Williams  
Director of Certification

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +44 (0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.